



ELECTRICAL INSTALLATION CONDITION REPORT
(Requirements for Electrical Installations – BS 7671 IEE Wiring Regulations)

DETAILS OF THE CLIENT

Peter Banyong

Address: Flat 2 Harrison House, 211 Westwood Road, London, IG3 8SE**PURPOSE FOR WHICH THIS REPORT IS REQUIRED**

This report must be used only for reporting on the condition of an existing installation.

Renewal

Date(s) : 01/04/21**DETAILS OF THE INSTALLATION****Occupier:** Tenants**Address:** Flat 2 Harrison House, 211 Westwood Road, London, IG3 8SE**Description of Premises:**Domestic ☒Commercial ☐Industrial ☐Other ☐**Estimated age of the Electrical Installation:**

15

Years

Evidence of Alterations or Additions:Yes ☐**If "yes" estimated**

6

Years

Date of previous Inspection:

N/A

Electrical Installation Certificate No. or previous Periodic Inspection report**Records of installation**

N

Records held**EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND TESTING****Extent of the Electrical installation covered by this report:**

All accessible areas, 40% Sampling

Agreed Limitations (including the reasons), if any, on the inspection and testing

None

Operational limitations including the reasons (see page No.)

This inspection has been carried out in accordance with BS 7671:2008, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in roof spaces and generally within the fabric of the building or under ground have not been inspected.

SUMMARY OF THE CONDITION OF THE INSTALLATION**General condition of the installation (in terms of electrical safety):**

Installation is of safe and sound condition overall

(Delete as appropriate)

An "Unsatisfactory" assessment indicates that dangerous and/or potentially dangerous conditions have been identified.

OBSERVATION AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

Referring to the attached Schedules of Inspection and Test Results and subject to the limitations;

N/A are made

[illegible]

*One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action:

DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signature(s) below, particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby Certify that the information on this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitation of the inspection and testing.

I/ further declare that in my/our judgement, the said installation was overall in satisfactory condition at the time of the inspection we carried out, and that it should be further inspected as recommended.

INSPECTION, TESTING AND ASSESSMENT BY:

Signature:



Name : (CAPITALS)

JERMAINE STEWART

Position:

ELECTRICIAN

Date:

01/04/21

REPORT REVIEWED AND CONFIRMED BY:

Signature:



Name : (CAPITALS)

JERMAINE STEWART

Date:

01/04/21

SCHEDULES AND ADDITIONAL PAGES

Schedule of items inspected Page No. 4,5,6,7

Additional pages, including additional source(s) data sheets: Page No(s):

Schedule of Circuit Details for the installation: Page No(s): 8

Schedule of Test Results for the installation: Page No(s):

The pages identified here form an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

NEXT INSPECTION

We recommend that this installation is further inspected and tested after an interval of not more than 5 YEARS

Provided that any items which have been attributed a Recommendation Code C1 and C2 (require urgent attention) are remedied without delay and as soon as possible respectively. Items which have been attributed a Recommendation Code C3 should be actioned as soon as practicable (see F).

DETAILS OF ELECTRICAL CONTRACTOR

Trading Title: Simple Spark

Address: 29 Albert Walk
North Woolwich

Postcode: E16 2NL

Telephone number: 7958398031

Fax number: /

Registration number: /

Branch number: /

(if applicable)

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Tick boxes and enter details, as appropriate

System Type(s)	Number and Type of Live Conductors			Nature of Supply Parameters			Characteristics of Primary supply Overcurrent Protective Device(s)		
TN-S	AC	✓	DC	Nominal Voltage U (1)	230	V	BS(EN)	1361	
TN-C-S	1-phase (2 wire)	✓	1-phase (3 wire)	Nominal frequency f (1)	50	Hz	Type	BS3161 Fuse HBC - Type 2	
TN-C	2-phase (3 wire)		3-phase (3 wire)	Prospective fault current (2/3)	0.96	kA	Rated current	100	A
TT	3-phase (4 wire)		2 pole	External earth fault loop impedance Ze (3/4)	0.59	Ω	Short-circuit capacity	33	kA
IT	3 pole		other	Number of supplies	1		(3) where more than one supply, the higher or highest values		
	Other (Please state)			NOTES:			(2) by enquiry or by measurement (4) by measurement		

PARTICULARS OF INSTALLATION AT THE ORIGIN

Tick boxes and enter details, as appropriate

Means of earthing	Details Installation Earth Electrode (where applicable)
-------------------	---------------------------------------------------------

Distributor's facility	✓	Type: (eg rod(s), tape etc)		Location:		Maximum Demand:		kVA/Amps
Installation earth electrode		Electrode resistance, RA:	Ω	Method of measurement:		Protective measures against electric Shock:		
# Main Switch or Circuit Breaker		Earthing and Protective Bonding Conductors						
Type (BS(EN)	60947-2 MCCB	Voltage Rating	230	V	Earthing conductor		Conductor csa	16 mm ²
No of Poles	2	Rated current I _n	100	A	Conductor material	Copper	Continuity check	✓ (✓)
Supply conductors: material	Copper	RCD operating current I _{Δn}	N/A	mA	Bonding of extraneous-conductive-parts (✓)			
Supply conductors: csa	25 mm ²	RCD operating time (at I _{Δn})	N/A	ms	Gas service	✓	Lighting	
					Water service	✓	Structural steel	
					Oil service		Other service(s)	

INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's supply intake equipment		
1.1	Service cable	OK	
1.2	Service cut-out/fuse(s)	OK	
1.3	Meter tails - distributor	OK	
1.4	Meter tails - consumer	OK	
1.5	Metering equipment	OK	
1.6	Means of main isolation (where present)	OK	
2.0	Presence of adequate arrangements for parallel or switched alternative sources	OK	
3.0	Automatic disconnection of supply		
3.1	Main earthing and bonding arrangements		
	* Presence and condition of distributor's earthing arrangement	OK	
	* Presence and condition of earth electrode arrangement	OK	
	* Adequacy of earthing conductor size	OK	
	* Adequacy of earthing conductor connections	OK	
	* Accessibility of earthing conductor connections	OK	
	* Adequacy of main protective bonding conductor size(s)	OK	
	* Adequacy of main protective bonding conductor connections	OK	
	* Accessibility of main protective bonding connections	OK	
	* Provision of earthing/bonding labels at all appropriate locations	OK	
3.2	FELV		
	* Source providing at least simple separation	N/A	
	* Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises	N/A	
3.3	Reduced low voltage		
	* Adequacy of source	N/A	
	* Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises	N/A	
4.0	Other methods of protection (where the methods of protection listed below are employed, details should be provided on separate sheets)		
4.1	Double insulation	OK	
4.2	Reinforced insulation	OK	
4.3	Use of obstacles	OK	
4.4	Placing out of reach	OK	
4.5	Non-conducting location	OK	
4.6	Earth-free local equipotential bonding	N/A	

4.7	Electrical separation for more than one item of equipment	N/A	
5. 0 Distribution equipment			
5.1	Adequacy of working space/accessibility of equipment	OK	
5.2	Security of fixing	OK	
5.3	Condition of insulation of live parts	OK	
5.4	Adequacy/security of barriers	OK	
5.5	Condition of enclosure(s) in terms of IP rating	OK	
5.6	Condition of enclosure(s) in terms of fire rating	OK	
5.7	Enclosure not damaged/deteriorated so as to impair safety	OK	
5.8	Presence of main switch(es), linked where required	OK	
5.9	Operation of main switch(es) (functional check)	OK	
5.10	Correct identification of circuit protective devices	OK	
5.11	Adequacy of protective devices for prospective fault current	OK	
5.12	RCD(s) provided for fault protection – includes RCBOs	OK	
5.13	RCD(s) provided for additional protection – includes RCBOs	OK	
5.14	RCD(s) provided for protection against fire – includes RCBOs	OK	
5.15	Manual operation of circuit-breakers and RCDs to prove disconnection	OK	
5.16	Presence of RCD retest notice at or near equipment where required	OK	
5.17	Presence of diagrams, charts or schedules at or near equipment where required	N/A	
5.18	Presence of non-standard (mixed) cable colour warning notice at or near equipment where required	N/A	
5.19	Presence of alternative supply arrangement warning notice(s) at or near equipment where required	N/A	
5.20	Presence of replacement next inspection recommendation label	OK	
5.21	Presence of other required labelling (specify)	N/A	
5.22	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	OK	
5.23	Protection against mechanical damage where cables enter equipment	OK	
5.24	Protection against electromagnetic effects where cables enter metallic enclosures	OK	
6.0 Distribution/final circuits			
6.1	Identification of conductors	OK	
6.2	Cables correctly supported throughout their length	OK	
6.3	Condition of insulation of live parts	OK	
6.4	Non-sheathed cables protected by enclosure in conduit, duct or trunking	N/A	
6.5	Suitability of containment systems for continued use (including flexible conduit)	OK	
6.6	Cables correctly terminated in enclosures (indicate extent of sampling in Section D of report)	OK	
6.7	Examination of cables for signs of unacceptable thermal and mechanical damage/deterioration	OK	
6.8	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	OK	
6.9	Adequacy of protective devices; type and rated current for fault protection	OK	
6.10	Presence and adequacy of circuit protective conductors	OK	
6.11	Co-ordination between conductors and overload protective devices	OK	
6.12	Cable installation methods/practices appropriate to the type and nature of installation and external influences	OK	
6.13	Cables where exposed to direct sunlight, of a suitable type	N/A	
6.14	Concealed cables installed in prescribed zones (see extent and limitations)	N/A	
6.15	Concealed cables incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage caused by nails, screws and the like where not in prescribed zones or not protected by 30 mA RCD (see extent and limitations)	N/A	
6.16	Provision of additional protection by 30 mA RCD for cables concealed in walls or partitions	OK	
6.17	Provision of additional protection by 30 mA RCD	OK	
	* Where reasonably likely to be used to supply mobile equipment for use outdoors	N/A	
	* For all socket-outlets of rating 20 A or less provided for use by ordinary persons	N/A	
6.18	Provision of fire barriers, sealing arrangements and protection against thermal effects	N/A	
6.19	Band II cables segregated/separated from Band I cables	N/A	
6.20	Cables segregated/separated from non-electrical services	N/A	
6.21	Termination of cables at enclosures (identify numbers and locations of items inspected in Section D)	OK	

	* Connections under no undue strain	OK	
	No basic insulation of a conductor visible outside an enclosure	OK	
	Connections of live conductors adequately enclosed	OK	
	Adequacy of connection at point of entry to enclosure (gland, bush or similar)	OK	
6.22	General condition of wiring systems	OK	
6.23	Temperature rating of cable insulation	OK	
6.24	Condition of accessories including socket-outlets, switches and joint boxes	OK	
6.25	Suitability of accessories for external influences	OK	
7.0 Isolation and switching			
7.1 Isolations			
	* presence and condition of appropriate devices	OK	
	* acceptable location	OK	
	* capable of being secured in the OFF position	OK	
	* correct operation verified	OK	
	* clearly identified by position and/or durable marking(s)	OK	
	* Warning label posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.2 Switching off for mechanical maintenance			
	* presence and condition of appropriate devices	OK	
	* acceptable location	OK	
	* capable of being secured in the OFF position	OK	
	* correct operation verified	OK	
	* clearly identified by position and/or durable marking(s)	OK	
7.3 Emergency switching/stopping			
	* presence and condition of appropriate devices	OK	
	* readily accessible for operation where danger might occur	OK	
	* correct operation verified	OK	
	* clearly identified by position and/or durable marking(s)	OK	
7.4 Functional switching			
	* presence and condition of appropriate devices	OK	
	* correct operation verified	OK	
8.0 Current-using equipment (permanently connected)			
8.1	Condition of equipment in terms of IP rating	OK	
8.2	Equipment does not constitute a fire hazard	OK	
8.3	Enclosure not damaged/deteriorated so as to impair safety	OK	
8.4	Suitability for the environment and external influences	OK	
8.5	Security of fixing	OK	
8.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire (indicate extent of sampling in Section D of report)	OK	
8.7 Recessed luminaires (e.g. downlighters)			
	* correct type of lamps fitted	OK	
	* installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar	OK	
	* no signs of overheating to surrounding building fabric	OK	
	* no signs of overheating to conductors/terminations	OK	
9.0 Location(s) containing a bath or shower			
9.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA	N/A	
9.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
9.3	Shaver sockets comply with BS EN 61558-2-5 or BS 3535	N/A	

9.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	OK	
9.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
9.6	Suitability of equipment for external influences for installed location in terms of IP rating	OK	
9.7	Suitability of equipment for installation in a particular zone	OK	
9.8	Suitability of current-using equipment for a particular position within the location	OK	
10.0 Other Special installations or locations			
List special locations present, if any. List the results of particular inspections applied.– a separate page is required for each location		N/A	

*** All Boxes must be completed**

Unacceptable condition state **C1** or **C2**

Outcome

✓ Indicates **Acceptable condition**

Improvement recommended state **C3**

Provide additional comment where appropriate on attached numbered sheets. C1, C2 and C3 coded items to be recorded in section F of the report.

LIM indicates a **limitation**

Further investigation required state **F/I**
(to determine whether danger or potential
(danger exists))

N/A indicates **Not applicable**

SCHEDULE OF ITEMS TESTED

✓	External earth loop impedance, Z_e	✓	Basic protection against direct contact by barrier or enclosure provided during erection
N/A	Installation earth electrode resistance, R_a	N/A	Insulation of non-conducting floors or walls
✓	Continuity of protective conductors	✓	Polarity
✓	Continuity of ring circuit conductors	✓	Earth fault loop impedance Z_s
✓	Insulation resistance between live conductors	✓	Verification of phase sequence
✓	Insulation resistance between live conductors and earth	✓	Operation of residual current devices
✓	Protection by separation of circuits	✓	Functional testing of assemblies
		N/A	Verification of voltage drop

EST INSTRUMENTS USED	
Earth fault loop impedance	Megger 1710 Multifunction Tester
Insulation resistance	Megger 1710 Multifunction Tester
Continuity	Megger 1710 Multifunction Tester
RCD	Megger 1710 Multifunction Tester
Other	N/A
Other	N/A

NOTES FOR RECIPIENT

THIS CERTIFICATE IS A VALUABLE DOCUMENT AND SHOULD BE RETAINED FOR FUTURE REFERENCE

This Electrical Installation Condition Report form is intended for the reporting on the condition of an existing electrical installation.

You should have received an original Certificate and the contractor should have retained a duplicate. If you were the person ordering this report, but not the owner of the installation, you should pass this Report, or a full copy of it, immediately to the user.

The original Report is to be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Report will provide the new owner with the details of the condition of the electrical installation at the time the Report was issued.

The 'Extent and Limitations' box should fully identify the extent of the installation covered by this Report and any limitations on the inspection and tests. The contractor should have agreed these aspects with you and any interested parties (Licensing Authority, Insurance Company, Building Society etc) before the inspection was carried out.

The Report will usually contain a list of recommended actions necessary to bring the installation up to the current standard. **For items classified as 'requires urgent attention', the safety of those using the installation may be at risk**, and it is recommended that a competent person undertake the necessary remedial work without delay.

For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a competent person. The maximum time interval recommended before the next inspection is stated in the Report under "Next Inspection."

DISTRIBUTION BOARD DETAILS														
DB ref.:	DB1	Z _s at this board (Ω):	0.59	I _{pr} at this board (kA):	0.98	Main switch type BSEN reference:	60947- type B	Rating:	100 Amps	Supply conductors:	25 mm ²	Earth:	16 mm ²	
Distribution board location:	HALLWAY	Supplied from:		Mains		No. Of phases:		Single		Supply protective device type: 2 MCB Type B BSEN reference:		Rating:		100 Amps
TEST RESULTS														
CIRCUIT DETAILS														

Circuit Reference	Circuit designation	Type of wiring	Reference method	Number of points served	Circuit conductors		Max.Disconnection time permitted (s)	Overcurrent devices				RCD	Circuit impedances Ω				Insulation resistance				Polarity	Maximum Measured Zs Ω	RCD	
					Live (mm ²)	cpc (mm ²)		Type BS EN	Rating (A)	Short circuit capacity (kA)	I _{an} mA		Ring final circuits only (Measured end to end)	All circuits (At least one column to be completed)	R ₁	R _n	r ₂	R ₁ +R ₂	R ₂	Phase /Phase M Ω			Phase /Neutral M Ω	Phase /Earth M Ω

1	CENTRAL HEATING	A	10 3	2	2.5	1.5	0.4	61008 RCD	40	6	N/A	0.87	N/A	N/A	N/A	0.16	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.28	N/A	N/A
2	COOKER	A	10 3	1	2.5	1.5	0.4	61008 RCD	32	6	N/A	1.08	N/A	N/A	N/A	0.17	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.3	N/A	N/A
3	RCD	N/A	N/A	1	16	N/A	0.4	61008 RCD	63	6	30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	>299	>299	>299	>299	✓	N/A	N/V	N/V
4	GENERAL RING	A	10 3	6	2.5	1.5	0.4	61008 RCD	32	6	N/A	1.08	0.17	0.18	0.21	0.28	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.29	N/A	N/A
5	BEDROOM RING	A	10 3	4	2.5	1.5	0.4	60898 Type B	32	6	N/A	1.44	0.17	0.17	0.19	0.2	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.24	N/A	N/A
6	LIVING + KITCHEN AREA LIGHTING	A	10 3	8	1.5	1.0	0.4	60898 Type B	6	6	N/A	3.49	N/A	N/A	N/A	0.18	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.26	N/A	N/A
7	BEDROOM LIGHTING	A	10 3	4	1.5	1.0	0.4	60898 Type B	6	6	N/A	3.49	N/A	N/A	N/A	0.19	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.29	N/A	N/A
8	RCD	N/A	N/A	1	16	N/A	0.4	61008 RCD	63	6	30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	>299	>299	>299	>299	✓	N/A	N/V	N/V
9	KITCHEN RING	A	10 3	5	2.5	1.5	0.4	61008 RCD	32	6	N/A	1.08	0.18	0.19	0.23	0.25	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.31	N/A	N/A
10	RING	A	10 3	3	2.5	1.5	0.4	61008 RCD	32	6	N/A	1.08	0.17	0.19	0.23	0.26	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.29	N/A	N/A
11	HALLWAY + BATHROOM LIGHTING	A	10 3	5	1.5	1.0	0.4	60898 Type B	6	6	N/A	3.49	N/A	N/A	N/A	0.15	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.33	N/A	N/A
12	SMOKE DETECTOR	A	10 3	2	1.5	1.0	0.4	60898 Type B	6	6	N/A	3.49	N/A	N/A	N/A	0.15	N/A	N/A	N/A	>299	>299	>299	>299	✓	0.39	N/A	N/A
13	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

CODES FOR TYPES OF WIRING								
A	B	C	D	E	F	G	H	O (other please state)
PVC/PVC CABLES	PVC CABLES IN METALLIC CONDUIT	PVC CABLES IN NON-METALLIC CONDUIT	PVC CABLES IN METALLIC TRUNKING	PVC CABLES IN NON-METALLIC TRUNKING	PVC/SWA CABLES	XLPE/SWA CABLES	MINERAL-INSULATED CABLES	